

AIRFOIL GRILLE - RECOMMENDED SPECIFICATION

GENERAL

Where indicated on plan drawings or described in schedules, furnish and install Airfoil Grilles as designed and manufactured by The Airolite Company LLC, Schofield, Wisconsin. Grilles shall be furnished in the configurations represented on the plan drawings and shall include supports, installation hardware and finishes as specified and required for a complete installation.

SUBMITTALS

Manufacturer shall submit shop drawings incorporating key plans, elevations, sections and details showing profiles, angles and spacing of components and frames; unit dimensions related to wall openings and construction; and, anchorage details and locations. Submit theoretical calculations prepared by a professional engineer specializing in the application of welding technology demonstrating that each fillet weld joining blade and frame members will withstand a minimum of 526 pounds of force in shear. Provide samples of manufacturer's finish and color charts showing the full range of finishes and colors available.

PRODUCTS

Architectural grilles shall be Airolite Airfoil Grilles as follows:

- Material: Extruded Aluminum, Alloy 6063-T5
- Airfoil Blade Thickness: 0.081" (2.06 mm), or as indicated.
- Grille Depth: Specify 3-1/2" (88.9 mm) to 6" (152.4 mm), or as Indicated.
- Perimeter Frame: Specify Aluminum Bar, Channel or Tube, or as indicated.
- Airfoil Blade Angle: Specify zero to 60-degrees, or as indicated.
- Horizontal Bar Spacing: Specify 2" (50.8 mm) to 12" (304.8 mm), or as indicated.

ALL-WELDED ASSEMBLY

All horizontal and perimeter frame members shall be joined with fillet welds concealed from view, unless the size of the grille makes bolted connections between grille sections necessary. Each weld shall be produced with the Pulsed Gas Metal Arc Welding (GMAW Mig) process. Blades shall be joined to perimeter frames with two 1-inch (25.4 mm) long fillet welds with a minimum 1/8-inch (3.175 mm) leg. Frames shall be joined at each corner with a full-length GMAW fillet weld with a minimum 1/8-inch (3.175 mm) throat.

STRUCTURAL DESIGN CRITERIA

Manufacturer shall design and furnish all supports required to withstand a wind force of not less than 25 pounds per square foot. Grilles 120-inches (3,048 mm) wide x 120-inches (3,048 mm) high will be fabricated and installed in multiple sections. Grille members, frames, mullions and anchor-ages shall be demonstrated to withstand the specified wind design load.