

## **K6744/CB6744 - RECOMMENDED SPECIFICATION**

### **GENERAL**

Furnish and install where indicated on plans or described in schedules drainable Louver Type K6744 (or CB6744) as designed and manufactured by The Airolite Company LLC, Marietta, Ohio. Louvers shall be furnished with bird screen, insect screen, supports, installation hardware and finishes as specified and as required for a complete installation.

### **SUBMITTALS**

Manufacturer shall submit shop drawings incorporating key plans, elevations, sections and details showing profiles, angles and spacing of louver blades and frames; unit dimensions related to wall openings and construction; and, anchorage details and locations. Provide samples of manufacturer's finish and color charts showing the full range of colors available. For each type of product specified, submit free area, air performance and water penetration ratings determined in accordance with AMCA Standard 500-L and licensed under the AMCA Certified Ratings Program.

### **PRODUCTS**

Louvers shall be drainable Louver Type K6744 with visible vertical mullions (or Louver Type CB6744 with recessed vertical mullions). Louvers shall be 4-inches (101.6 mm) deep and assembled entirely from extruded aluminum components. Blades and frames shall be 0.081-inch (2.0 mm) thick extruded aluminum, alloy 6063-T5. Blades shall be stationary, incorporate drainable gutters, and be spaced 3-1/4-inches (82.5 mm) on center. Jamb frames shall incorporate drainable gutters to ensure resistance to water penetration.

### **STRUCTURAL DESIGN CRITERIA**

Manufacturer shall design and furnish all supports required to withstand a wind force of not less than 25 pounds per square foot (100 mph). Louvers 120-inches wide x 84-inches high or 84-inches wide x 120-inches high will be fabricated and installed in multiple sections. Louver blades, frames, mullions and anchorages shall be demonstrated to withstand the specified wind design load.

### **PERFORMANCE RATINGS**

FREE AREA:	8.98 Square Feet (0.84 m <sup>2</sup> )
MINIMUM FREE AREA VELOCITY	
at Beginning Point of Water Penetration:	1,151 fpm (5.85 m/s)
MINIMUM AIR VOLUME FLOW RATE	
at Beginning Point of Water Penetration:	10,336 cfm (4.885 m <sup>3</sup> /s)
MAXIMUM STATIC PRESSURE	
at Beginning Point of Water Penetration:	0.20 in. H <sub>2</sub> O (0.040 kPa)