

## **SCH501X - RECOMMENDED SPECIFICATION**

### **GENERAL**

Furnish and install where indicated on plans or described in schedules Storm Class Louver Type SCH501X as designed and manufactured by The Airolite Company LLC, Schofield, Wisconsin. Louvers shall be furnished with bird screen, insect screen, supports, installation hardware and finishes as specified and as required for a complete installation.

### **SUBMITTALS**

Manufacturer shall submit certified reports demonstrating that Louver Type SCH501X is tested by UL Laboratories Inc in accordance with ASTM E330-02, Standard Test Method for Structural Performance of Exterior Windows, Doors, Skylights, and Curtain Walls by Uniform Static Air Pressure Difference, to a maximum wind design load of +/- 200 psf (9.6 kPa) in compliance with the Florida Building Code. Manufacturer shall submit shop drawings incorporating key plans, elevations, sections and details showing profiles, angles, and spacing of louver blades and frames; unit dimensions related to wall openings and construction; and, anchorage details and locations. Provide samples of manufacturer's finish and color charts showing the full range of colors available. For each type of product specified, submit free area, air performance, water penetration and wind-driven rain water penetration ratings determined in accordance with AMCA Standard 500-L and licensed under the AMCA Certified Ratings Program.

### **PRODUCTS**

Louvers shall be Storm Class type and rated to resist water penetration under wind-driven rain conditions. Louvers shall be 5-inches (127 mm) deep and assembled entirely from extruded aluminum components. Blades and frames shall be 0.081-inch (2 mm) thick aluminum, alloy 6063-T5. Blades shall be horizontal, inverted-V type with a center hook and spaced 2-inches (50.8 mm) on center.

### **STRUCTURAL DESIGN CRITERIA**

Manufacturer shall design and furnish all supports required to with-stand wind forces in accordance with the Florida Building Code. Louvers larger than 84-inches (213 cm) wide x 120-inches (305 cm) high or 120-inches (305 cm) wide x 84-inches (213 cm) high will be fabricated and installed in multiple sections. Louver blades, frames, mullions and anchorages shall be demonstrated to withstand the specified wind design load.

### **PERFORMANCE RATINGS**

FREE AREA:	6.80 Square Feet (0.63 m <sup>2</sup> )
MINIMUM FREE AREA VELOCITY	
at Beginning Point of Water Penetration:	1,250 fpm (6.35 m/s)
MINIMUM AIR VOLUME FLOW RATE	
at Beginning Point of Water Penetration:	9,337 cfm (4.41 m <sup>3</sup> /s)
MAXIMUM STATIC PRESSURE	
at Beginning Point of Water Penetration:	0.18 in. H <sub>2</sub> O (0.045 kPa)