

## **SCV602MD - RECOMMENDED SPECIFICATION**

### **GENERAL**

Furnish and install where indicated on plans or described in schedules Storm Class Louver Type SCV602MD as designed and manufactured by The Airolite Company LLC, Schofield, Wisconsin. Louvers shall be furnished with bird screen, insect screen, supports, installation hardware and finishes as specified and as required for a complete installation. Miami-Dade Approved Product for use in open structures or installations where the enclosed space is designed to accommodate water infiltration (wet rooms).

### **SUBMITTALS**

Manufacturer shall submit shop drawings incorporating key plans, elevations, sections and details showing profiles, angles and spacing of louver blades and frames; unit dimensions related to wall openings and construction; and, anchorage details and locations. Provide samples of manufacturer's finish and color charts showing the full range of colors available. For each type of product specified, submit free area, air performance, water penetration and wind-driven rain ratings determined in accordance with AMCA Standard 500-L and licensed under the AMCA Certified Ratings Program.

### **PRODUCTS**

Louvers shall be sightproof Louver Type K605MD. Louvers shall be 5-inches (127 mm) deep and assembled entirely from extruded aluminum components. Blades and frames shall be 0.081-inch (2 mm) thick aluminum, alloy 6063-T5. Blades shall be horizontal, inverted-V type with a center hook and spaced 2-inches (50.8 mm) on center.

### **STRUCTURAL DESIGN CRITERIA**

Louvers shall be tested in accordance with Miami-Dade protocols TAS-201, TAS-202 and TAS-203 and approved for open structure building envelope protection for single unit sizes up to 4-feet wide x 8-feet high for wet rooms. Louvers shall be tested for wind forces up to 150 psf. Louvers must be secured to a structural substrate in accordance with Dade County Product Approval Drawings. In addition, the structural substrate must be designed to accommodate the point loads transferred by the louvers when subject to the design wind loads.

### **PERFORMANCE RATINGS**

FREE AREA:	5.88 Square Feet (0.55 m <sup>2</sup> )
MINIMUM FREE AREA VELOCITY	
at Beginning Point of Water Penetration:	above 1,250 fpm (6.35 m/s)
MINIMUM AIR VOLUME FLOW RATE	
at Beginning Point of Water Penetration:	7,350 cfm (3.47 m <sup>3</sup> /s)
MAXIMUM STATIC PRESSURE	
at Beginning Point of Water Penetration:	0.12 in. H <sub>2</sub> O (0.030 kPa)